

ADDENDUM #2
16TH STREET Bridge Rehabilitation 2020
January 28, 2020

The following Addenda items shall be applied to the *Construction Contract Documents and Specifications* for the 16th Street Bridge Rehabilitation.

Questions Received:

1. Q: There is a “statement” in the back of the spec’s that says the work consists of placing an approved hot poured joint and crack sealant in....asphalt pavements.

I assume this does not apply to this project? I think you said the crack fill project would be later in the year.?

A: Hot filled crack fill is not part of the scope of this project. There will be crack filling on the bridge but it is to be performed by others.

2. Q: Can you clarify Bid Item 15, it says to include material and labor for any surface prep not included by D5. What is D5 referring to?

A: D5 is a reference to item 11.

Item 11 gets the surface to a near white. Any vacuuming, air lancing, wiping, masking, etc. required in between blasting and painting should be included in item 15.

3. Q: Bid item 6, Protection of Stream from debris shows LS 9. What is the intent for this quantity or should this be LS 1?

A: The quantity is 1.

Additional Information:

Additional or revised items included on the City website (Contractor to download):

- 16th Street Bridge Rehabilitation -Addendum #2.pdf

As a reminder, the Bid submittal deadline is 2:00pm January 31, 2020. Please continue to submit all questions via email to cspaulding@riflco.org.